

شركة البدرى للأعمال الكهروميكانيكية

إحدى شركات مجموعة البدرى للتنمية والاستثمار

BADRY Electro-Mechanical Works Co.

MEP CONTRACTOR

GEOTHERMAL GHP HWAG SOLUTION

ORANA Food Plant HVAC Systems Upgrade @ Badr City

FACILITY GHP / HVAC SYTEMS 300 TONs

Quotation # 16230-00-010-1434, Rev 00 - Feb. 2020











BADRY MEP

Electro-Mechanical Works Co.

6B, Sixth October St., Manshiet Al Sad Al Aaly, Al-Salam, Cairo, Egypt.

P.O Box 1527 Alf Maskan, Cairo, Egypt. Tel: +202 219 06 401, +202 219 06 362

Fax: +202 219 06 823 - Cell: +20 100 57 43 852

E-mail: mep@badrygroup.com Web : www.Badrygroup.com



BADRY MEP Co.

Quotation

BADRY GROUP Member - Code 010

P.O.Box 1527 Alf Maskan Cairo 11777, Egypt

Phone 21906401 Fax 21906823

DATE 25/02/2020 Quotation # 16230 (Rev 0) Customer ID 1434

Quotation valid until: 30/04/2020

Prepared by: Gehad Salah

Geothermal GHP Solution

Facility HVAC Systems - 300 Ton

Quotation For:

Terms or

Special Cond.;

Project Geothermal GHP HVAC Solution for Badr Plant

Name Mr. Mahendra Dhote

Company/Auth. ORANA

Address Plot 145, Area 250 Yard, Robeyky - Badr City

Tel / Fax 02 23 10 82 23 / 23 10 82 27

Cel / Mob +2 0109 532 2552 E-Mail **msd@orana.com.eg**

| SALES PERSON | QUOTE NUMBER | DELIVERY | SHIP VIA | SITE | TERMS |
|--------------|----------------------|------------------------|------------|-----------|--------------|
| Gehad Salah | 16230-0 / 010 / 1434 | 12 Months (10 + 2) W.M | LAND - DTD | Badr City | Due on Order |
| | | | | | |

20% In Advance (A.P), R.T (Raise To) 50% Material, R.T 95% Install Invoices, 05% RET. / Delivery

Delivery 10 Working Months (W.M) From W.O & A.P, Design, Approved WSDs (2 W.M) Design Recipt

| CODE | DESCRIPTION | BOQ | ADD / ENG | AMOUNT USD) |
|-------------------------|---|---------------|------------|---------------|
| VENT | GEOTHERMAL SYSTEM FOR AREA VENTILATION Acc. To. Table D-1: BOQ - Geothermal Ground Coupled System for the Ventilation of Production Area | 660,000 | 40,000 | USD 700,000 |
| ACND | GEOTHERMAL SYSTEM FOR AIR CONDITIONING Acc. To. Table D-2: BOQ - Geothermal Ground Coupled System for the Air Conditioning of the Adminstrative Area | 960,000 | 40,000 | USD 1,000,000 |
| HEAT | GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING Acc. To. Table D-3: BOQ - Geothermal Ground Coupled System for the Heating Steam of Food Production Area | 760,000 | 40,000 | USD 800,000 |
| A. Client is Require | d to Provide at Site (Our Prices Exclude Any of); | | SUBTOTAL | USD 2,500,000 |
| 1- Site Facilities; Pov | wer, Lighting, Water, Drainage - Sources | | VAT TAX | USD 350,000 |
| 2- Storage Area, Site | e Office, Lisences, Permits from Any /others Entrance & Exist | t Fees | SOC. INSUR | USD 100,000 |
| B. Quote Prices bas | OTHERs | USD 50,000 | | |
| C. ADD / ENG expre | TOTAL | USD 3,000,000 | | |

D. Others is a non refund cost values express Mobilization, Accomodation

If you have any questions concerning this quotation contact Ms. Gehad Salah Tel +20 2 219 06 401, Fax +20 2 219 06 823, hasoegypt@gmail.com, mep@badrygroup.com

THANK YOU FOR YOUR BUSINESS!



شركة البدري لأعمال التهويه والثيريد والتكيف والتنفئة GEOTHERMAL SYSTEM AIR EQUIPMENT CALCULATION

Table C - Air Equipments Calculation

احدى شركات مجموعة البدرى التتمية والاستثمار
BADRY HVAC Warks Co.

Ventilation for Production Area Project - Quote 16231-00

Table C-1: Air Equipment Calculation for the Ventilation for Production Area Project

| | Production Area Ventilation - Water To Air "a" - GHP/ AHU (s) Calculation | | | | | | | | | | | |
|-----|---|-------|--------|-----------|-------------------------|-------------|------------------------------|-------|---------------|----------------------|----------------------|-------------|
| S.N | Area Description | Class | ISO | Area (m²) | Area (ft ²) | Height (ft) | Volume (ft ³) | АСРН | CFM Steady | Add CFM Fresh Air | Add CFM Heat Load | CFM SUM |
| 1 | Production Area | N/A | N/A | 308 | 3315 | 33 | 109395 | 15 | 27,349 | 0 | 2,000 | 29,349 |
| 2 | Corridors Area | N/A | N/A | 105 | 1130 | 33 | 37290 | 12 | 7,458 | 746 | 400 | 8603.80 |
| 3 | Services Area | N/A | N/A | 37 | 398 | 10 | 3980 | 20 | 1,327 | 199 | 522 | 2047.67 |
| | | | | | | | | | | | | |
| а | AHU(s) / G.H.P(s) | 8,000 | 40,000 | CFM | 20 | 100 | TR | 5 | 36,133 | 945 | 2,922 | 40,000 |
| | | CFM | ALL | | Ton | ALL | • | QTY | | | | CFM_Total |
| | | A.H.U | | | G.H.P | Geothermal | Heat Pumps | G.H.P | | | | |



شركة البدري لأعمال التهويه والتبريد والتكيف والتنفئة GEOTHERMAL SYSTEM AIR EQUIPMENT CALCULATION

Table C - Air Equipments Calculation

احدى شركات مجموعة البدرى للتنمية والاستثمار
BADRY HVAC Warks Co.

Air Condition for Adminstrative Area Project - Quote 16232-00

Table C-2: Air Equipment Calculation for the Air Condition for Adminstrative Area Project

| | Production | n Area | Venti | lation - | Water | To Wa | ter "b" | - GHP/ | AHU (s |) Calcu | ılation | |
|-----|-------------------|--------|--------|-----------|-------------------------|-------------|------------------------------|--------|---------------|----------------------|--|----------------------|
| S.N | Area Description | Class | ISO | Area (m²) | Area (ft ²) | Height (ft) | Volume (ft ³) | АСРН | CFM Steady | Add CFM Fresh Air | Add CFM Heat Load | CFM SUM |
| 1 | Ground Floor Area | N/A | N/A | 182 | 1960 | 10 | 19600 | 30 | 9,800 | 1,960 | 2,000 | 13,760 |
| 2 | First Floor Area | N/A | N/A | 173 | 1862 | 10 | 18620 | 30 | 9,310 | 1,862 | 2,000 | 13,172 |
| 3 | Services Area | N/A | N/A | 145 | 1560 | 10 | 15600 | 36 | 9,360 | 1,872 | 1,836 | 13,068 |
| | | | | | | | | | | | | |
| b | AHU(s) / G.H.P(s) | 10,000 | 40,000 | CFM | 25 | 100 | TR | 4 | 28,470 | 5,694 | 5,836 | 40,000 |
| | | CFM | ALL | | Ton | ALL | | QTY | | | <u>. </u> | CFM _{Total} |
| | | A.H.U | | | G.H.P | Geothermal | Heat Pumps | G.H.P | | | | |





إحدى شركات مجموعة البدرى للتنمية والاستثمار
BADRY Electro-Mechanical Works Co.

Geothermal System Air Equipment Calculation

Table C – Air Equipment's Calculation

Heating Steam for Food Production Project - Quote 16233-00

Table C-3: Air Equipment Calculation for Heating Steam for Food Production Project

| Heating Water with Steam Heat Exchan | gers - Shell and | l Tube Exchanger |
|--|------------------|------------------------------|
| Steam is on the Shell side | | _ |
| Product to heat is on the Tube Side | | |
| Temperature in | 68 | F |
| Temperature out | 320 | F |
| Delta T | 252 | F |
| Gallons to Heat | 5.00 | US GPM |
| Gallons to Heat | 4 | IMP Gall / Minutes |
| Gallons to Heat | 250 | Imp Gallons / Hour |
| Based on S.Gravity | 2498 | Lbs / Hour |
| Heating | 19 | Litres / Minutes |
| Specific Heat of Liquid (Cp) | 1 | BTU / LB F |
| Specific Gravity | 1 | |
| Steam Pressure | 150 | psig |
| Latent Heat at Steam Pressure | 880 | BTU / LB |
| Safety Factor (Eff. H. Exch) | 85 | % Efficiency |
| | 740,586 | BTU / Hour Required |
| | 186,628 | Kcal / Hr to Exchanger |
| Load of Heat Exchanger | 842 | LBS / Hour of Steam Required |
| BHP - Using Heat Exchanger | 24.4 | BHP ☆ |
| Direct Injection of Steam into Water | 630.0 | LBS / Hour of Steam Required |
| BHP - Direct injection of Steam into water | 18.3 | BHP ☆ |

Geothermal / Ground Source Coupled Heat Pump – Water To Water G.H.P:

Total Heat Load =

Tel.: (+202) 22958530 - 22955487

186,628 K.Cal/Hr (Heat Steam for Production)

+ 113,372 K.Cal/Hr (Hot Water for Cooking)

Total Heat Load = 300,000 K.Cal/Hr = 1,200,000 BTU/Hr

Total Heat Load = 100 Ton

Using: #3 G.H.P (2+1); 2 Operation + 1 Backup / Standby

Each of 50 Ton, Water To Water Heat Pump (Ground Coupled) With Dedicated Control System (DDC)

6B, 60 October st., Menshiat El-Sad ElAley - El Salam, Cairo, Egypt.

Fax: (+202) 22995860

٦ب شارع ٦ أكتوبر منشيه السد العالى السلام القاهرة،

تليفون : ۲۲۹۰۸۵۳۰ – ۲۲۹۰۵۶۸۷ (۲۰۲+) فاکس : ۲۲۹۰۸۵۳۰ (۲۰۲+)



إحدى شركات مجموعة البدرى للتنمية والاستثمار
BADRY Electro-Mechanical Works Co.

Table A - Per TON's Cost Calculation - 2020

Geothermal System Costing Calculation

Overall Geothermal System Project – Per Ton Calculations

Table A: Geothermal HVAC Systems Construction Cost & Per Ton Calculation:

| S.N | Area | HVAC System | Load (Ton) | Notes | Total COST (USD) | Per Ton (USD) |
|-----|--------------------|--------------|-----------------------------|----------------------------|---------------------|------------------|
| 1 | Production Area | Ventilation | 100 | Cool Only | 700,000 | 7,000 |
| 2 | Adminstration Area | Air Condtion | 100 | Cooling + Hydronic Warming | 1,000,000 | 10,000 |
| 3 | Production Area | Heating | 100 Heating (Water / Steam) | | 800,000 | 8,000 |
| | | | | | | |
| S | Facility HVAC | SUM | 300 | Exclude TAXs | 2,500,000 | 8,333 |
| | | | | Taxes & Social Insur. | 450,000 | 1,500 |
| | | | | Others, Mobilization | 50,000 | 167 |
| Р | Facility HVAC | Total | 300 | Enclude TAXs | 3,000,000 | 10,000 |
| | | | TON | | Total HVAC COST | Per Ton Cost |
| | | | | | | |

Geothermal Facility HVAC Systems Construction Cost:

- Total Facility HVAC Systems Load = 300 Ton
- Total Facility HVAC Systems Cost = 3,000,000 USD
- Per Ton HVAC Systems Cost = 10,000 USD

Notes of Pricing:

- 1) Above HVAC Facility Systems are Economical Solution (60% Energy Reduction) with 5Y Warranty from 25Y Lifetime, of (3,000,000 USD), China GHPs total price = 1,110,000 USD (37% of Total System Price) and Per Ton Price (10,000 USD) based on China Origin GHPs via brands same as AMRTA, NE and Mango.
- 2) Hi-Level Solution (70% Energy Reduction) with 10Y Warranty from 30Y Lifetime for HVAC Facility Systems will be of (5,250,000 USD), US GHPs total price = 3,360,000 USD (64% of Total System Price) and Per Ton Price (17,500 USD) based on US Origin GHPs via brands same as Northern, Bard and Thermal-Air.

6B, 60 October st., Menshiat El-Sad ElAley - El Salam, Cairo, Egypt.

Tel.: (+202) 22958530 - 22955487 Fax: (+202) 22995860

آب شارع آ أكتوبر منشيه السد العالى . السلام . القاهرة . تليفون : ٢٢٩٥٨٥٣٠ - ٢٢٩٥٨٥٣٠ (٢٠٢+) فاكس : ٢٢٩٩٥٨٦٠ (٢٠٠+)



إحدى شركات مجموعة البدرى للتنمية والاستثمار

BADRY Electro-Mechanical Works Co.

Geothermal HVAC System Savings Calculation

Table B – Comparison of Energy Sources Cost Calculation - 2020

Geothermal HVAC System Project – SAVINGs Calculations

Table B: Geothermal HVAC Systems Compared Energy Cost & Savings:-

| | Traditional Electric Resistant HVAC Systems Annual Costs | | | | | | | | | | | |
|----------------|--|----------------|---------|-----------|-------------------------|------------------------------|-----------------|---------------|---------------|------------------------------------|--|--|
| S.N | Area | HVAC System | l oad l | | SUM Annual Energy | SUM Annual Maintenance | TOTAL Annual | | | | | |
| J.III | 74.00 | Tivao oyaidiii | (Ton) | KWH (s) | Cost/USD | MMBTU (s) | Cost / USD | COST (USD) | COST (USD) | T. HVAC COST (USD) 35,000 | | |
| 1 | Production Area | Ventilation | 100 | 150,000 | 15,000 | 0.00 | 0.00 | 15,000 | 20,000 | 35,000 | | |
| 2 | Adminstration Area | Air Condtion | 100 | 650,000 | 65,000 | 0.00 | 0.00 | 65,000 | 50,000 | 115,000 | | |
| 3 | Production Area | Heating | 100 | 200,000 | 20,000 | 16,667 | 100,000 | 120,000 | 30,000 | 150,000 | | |
| S _T | Facility HVAC | SUM | 300 | 1,000,000 | 100,000 | 16,667 | 100,000 | 200,000 | 100,000 | 300,000 | | |

| | Geothermal GHP Heat Pump HVAC Systems Annual Costs | | | | | | | | | | | | |
|----------------|--|--------------|---------------|---------|---------------|-----------|------------|-------------------------|-------------------------------------|----------------------------|--|--|--|
| S.N | Area | HVAC System | Load (Ton) | • | erational Ene | | TY / COST) | SUM Annual Energy | SUM Annual <u>Maintenance</u> | TOTAL Annual G. HVAC | | | |
| | | | | KWH (s) | Cost/USD | MMBTU (s) | Cost / USD | COST (USD) | COST (USD) | COST (USD) | | | |
| 1 | Production Area | Ventilation | 100 | 50,000 | 5,000 | 400 | 2,400 | 7,400 | 6,667 | 14,067 | | | |
| 2 | Adminstration Area | Air Condtion | 100 | 200,000 | 20,000 | 700 | 4,200 | 24,200 | 6,667 | 30,867 | | | |
| 3 | Production Area | Heating | 100 | 50,000 | 50,000 5,000 | | 18,400 | 23,400 | 6,667 | 30,067 | | | |
| S _G | Facility HVAC | SUM | 300 | 300,000 | 30,000 | 4,167 | 25,000 | 55,000 | 20,000 | 75,000 | | | |

Geothermal Facility HVAC Systems Savings:

- Applied GHP HVAC Systems is 25% of existing Electric Resistant Systems for same load of 300 Tons
- Applied GHP HVAC Systems has the Lowest Operating Cost more over Lowest CO2 Emissions and so Lowest Sound Ratings
- Estimated Annual Savings for HVAC Operations & Maintenance = 225,000 USD "Per Year"

Notes of Savings:

- 1) Estimated Energy costs based on industrial applications tariff @ EGY 2020 via 6 USD for MMBTU Natural Gas and 10 Cent for KWH, and within given data that operation through 8-10 working hours a day at facility.
- 2) Higher Energy (Qty & Cost) Savings due to the existing Air Condition system based on Mini Split AC Units and Electric Heaters and Boilers for Administrative heating and air conditions in which all will be replaced by economical GHP Centralized HVAC Systems.
- 3) GHP HVAC Systems all will be higher efficiency, comfort and echo friendly plus lowest cost compared to existing traditional Electric Resistant HVAC System especially the Ventilation System for the production area it will be humidity leveling and rating being controlled and with colder fresh air rather than founded ventilated air with hotter air and higher humidity containing.

6B, 60 October st., Menshiat El-Sad ElAley - El Salam, Cairo, Egypt.

آب شارع آ أكتوبر منشيه السد العالى . السلام . القاهرة . تليفون : ۲۲۹۵۸۵۳۰ – ۲۲۹۵۵۵۲۷ (۲۰۲+) فاكس : ۲۲۹۹۵۸۲۰ (۲۰۲+)

Tel.: (+202) 22958530 - 22955487 Fax: (+202) 22995860 (+۲۰۲) ۲۲۹۹٥٨٦٠ فاکس : (+۲۰۲) ۲۲۹۹٥۸۵۲۰



إحدى شركات مجموعة البدرى للتنمية والاستثمار

BADRY Electro-Mechanical Works Co.

Geothermal HVAC System Payback Calculation

Table E – Geothermal HVAC System PAY-BACK Calculation - 2020

Geothermal HVAC System Project – PAY-BACK Calculations

Table E: Geothermal HVAC Systems PAY-BACK:-

| G | Facility HVAC Systems | 300 | 3,000,000 | 10,000 | 75,000 |
|-------------------------|------------------------------|-----|--------------------|--|--|
| Ged | othermal GHP Heat Pumps | TON | First Base COSTs | Per Ton First Base Cost | Energy + Maintenance Annual COSTs |
| | | | | | |
| E Facility HVAC Systems | | 300 | 1,650,000 | 5,500 | 300,000 |
| Tra | iditional Electric Resistant | TON | First Base COSTs | Per Ton First Base Cost | Energy + Maintenance Annual COSTs |
| | | | | | |
| S | SAVINGs | 300 | 1,350,000 | 4,500 | 225,000 |
| | | TON | First Base SAVINGs | Per Ton First Base Saving | Energy + Maintenance Annual SAVINGs |
| | | | | | |
| P PAY-BACK | | 300 | 1,350,000 | 225,000 | 6 |
| | | TON | First Base SAVINGs | Energy + Maintenance Annual SAVINGs | YEARs |
| | | | | | |

Geothermal Facility HVAC Systems Payback year's calculation:

- Estimated Payback years for Submitted Geothermal GHP HVAC Systems of 300 Tons is 6 Years.
- Successful Geothermal HVAC System Paybacks are within 5 10 Years.

Fax: (+202) 22995860

- Noting the Life-Time of existing Air Condition (Split AC Units) is around 5 7 Years, compared to Geothermal HVAC System of 30 Years Life-Time Thus makes additional added value for GHP savings and Payback years.
- HVAC System Economics lead to its Bottom Line equals the sum of First Base Costs (Initial Construction and building Costs) and the Energy Costs (for Operation) and the Maintenance Cost (Preventive & Services Repair).
- First Base Cost is greatly influenced by effective design.
- Geothermal HVAC System have the Higher Economic Benefits of Performance, Energy Efficient, Comfortable Operation, Reduction of Energy Costs, Payback rates and generally Best Life Cycle Costs.

6B, 60 October st., Menshiat El-Sad ElAley - El Salam, Cairo, Egypt.

Tel.: (+202) 22958530 - 22955487

آب شارع ۲ أكتوبر منشيه السد العالى . السلام . القاهرة .
 تليفون : ۲۲۹۵۸۵۳۰ – ۲۲۹۵۸۵۳۷ (۲۰۲+) فاكس : ۲۲۹۹۵۸۵۳۰ (۲۰۲+)



Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AREA VENTILATION -- Project Quote 16231-00

| | | | | Oee 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 1 | Geothermal System Design & Ground Testing | | | | | | | | |
| | Ground Geothermal Sytem Testing & Designing, provides the designer with accurate information on the thermal conductivity, loop design can be optimized and the path of of piping and Bore-Holes. Tests with Field Testing Appartus will be conducted by drilling borehole and adding loop with hot water from a portable electric heater is circulated. Data log is run over 48 hours and energy absorbed by the ground is measured so that the conductivity and diffusivity could been calculated. Then, Submitting of Trenched Horizontal / Vertical Loop Design, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping | | | | | | | | |
| 1-a | Ground Testing for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |
| 1-b | Ground Loop Design for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AREA VENTILATION -- Project Quote 16231-00

| | | | | Occ. 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|--|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 2 | Ground Closed Loop Hydrulic Piping Works | | | | | | | | |
| | Under Ground Geothermal closed loop; Trenched Horizontal / Drilled Vertical, Loop Piping works via HDPE System, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping of HDPE material c/w all required fittings to act as a heat exchanger same to cooling coil. Item complete with Backfill & Grouts for the piping jacket avoiding Air Gaps or seprations via grouting with Thermal Grouts of 60% Quartezil and 20% Cement, 10% Fly Ash, 10% Sand. Hydrulic Fluid of Antifreeze Water Based Solution as a water source refrigrant for Heat Pump to be supplied and equiped. | | | | | | | | |
| 2-a | Trenched horizontal HRZ Loop with 10 ft depth, Bore-hole 4 Inch | Ton | 50 | BADRY | 600 | 30,000 | 900 | 45,000 | 75,000 |
| 2-b | Drilled Vertical VER Loop with 200 ft depth, Bore-hole 6 Inch | Ton | 50 | BADRY | 800 | 40,000 | 1200 | 60,000 | 100,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AREA VENTILATION -- Project Quote 16231-00

| | | | | O.CC 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 3 | Geothermal System Equipments (GHP Equipments) | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal water source Heat Pump with R-410a Refrigrant with wider fluid operating range and additional insulation of internal co-axial coils, thermal expansion TX Valves and heat exchangers optimized for geothermal operating conditions. GHP to be designed and supplied with Variable Flow System c/w two-way isolating valves at each heat pump that shut off the flow when the compressors is not runing. Heat Pump to be modulated and equipeed with variable frequency drive (VFD) | | | | | | | | |
| 3-a | GHP c/w VFD for Variable Flow, 20 Ton (Cool Only) | No | 5 | AMRTA | 28000 | 140,000 | 4000 | 20,000 | 160,000 |
| 3-b | GHP c/w VFD for Variable Flow, 25 Ton (Cool + Warm) | No | 0 | AMRTA | 53000 | 0 | 7000 | 0 | 0 |
| 3-с | GHP c/w VFD for Variable Flow, 50 Ton (Heating / Child) | No | 0 | AMRTA | 67000 | 0 | 8000 | 0 | 0 |
| 3-d | Rooftop Unit with Enthalpy Wheel | No | 1 | Mc-Quay | 49000 | 49,000 | 6000 | 6,000 | 55,000 |
| 3-е | Templifier Water to Water Heat Recovery | No | 1 | Mc-Quay | 41000 | 41,000 | 4000 | 4,000 | 45,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AREA VENTILATION -- Project Quote 16231-00

| | | | | Oee 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 4 | Pumping & Mechanical Room Works | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal system redundant pump package system to meet the design flow and to be connected and controlled with VFD of GHP. System to be complete with Supply & Return Headers @ Mechanical Rooms c/w pipes, fittings, taps and valves for supply / return lines and expansion tanks and air seprators to act the whole system operation more over system flushing; air removing from ground loop into piping | | | | | | | | |
| 4-a | Pumping System for Flow (1-Operation +1-Standby) | Pkg | 1 | Grundfos | 28000 | 28,000 | 4000 | 4,000 | 32,000 |
| 4-b | Mechanical Room Works c/w Headers, Valves, Accessories | LS | 1 | BADRY | 12000 | 12,000 | 6000 | 6,000 | 18,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AREA VENTILATION -- Project Quote 16231-00

| | | | | Off 1 | Supp | oly (USD) | Erection (USD) | | Total Supply | |
|-----|---|-----------------------------|-----|------------------|--------------|-----------|----------------|---------|---------------------|--|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) | |
| 5 | Delivery / Distribution System | | | | | | | | | |
| 5-1 | SITC Water Transfer / Piping System c/w Valves & Fittings | LS | 0 | BADRY | 75000 | 0 | 25000 | 0 | 0 | |
| 5-2 | SITC Air Transfer / Ducting System c/w Registers & Dampers | LS | 1 | BADRY | 55000 | 55,000 | 20000 | 20,000 | 75,000 | |
| 5-3 | SITC Radiant Floor Warming System c/w Outlets | LS | 0 | BADRY | 85000 | 0 | 25000 | 0 | 0 | |
| 5-5 | Civil / Arch. Ancilaary Works to furnish Distribution System | LS | 1 | BADRY | 0 | 0 | 35000 | 35,000 | 35,000 | |
| 6 | Control & Management System | | | | | | | | | |
| 6-1 | DDC Control System | LS | 1 | Rockwell | 19000 | 19,000 | 4000 | 4,000 | 23,000 | |
| 6-2 | BMS / HDMI Operation System with PLC | LS | 1 | Rockwell | 22000 | 22,000 | 5000 | 5,000 | 27,000 | |
| 7 | Testing & Balance | | | | | | | | | |
| 7-1 | Testing & Ballancing of HVAC / Ducting / Piping Systems of Each Area Acc. To ASHARE / SMACNA / ISO Classification | LS | 1 | BADRY | 0 | 0 | 15000 | 15,000 | 15,000 | |
| S1 | GEOTHERMAL - SUM / VENTILATION WORKS | Seven Hundred Thousands USD | | | | | | 700,000 | | |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AIR CONDITIONING -- Project Quote 16232-00

| | | | | O.CC 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 1 | Geothermal System Design & Ground Testing | | | | | | | | |
| | Ground Geothermal Sytem Testing & Designing, provides the designer with accurate information on the thermal conductivity, loop design can be optimized and the path of of piping and Bore-Holes. Tests with Field Testing Appartus will be conducted by drilling borehole and adding loop with hot water from a portable electric heater is circulated. Data log is run over 48 hours and energy absorbed by the ground is measured so that the conductivity and diffusivity could been calculated. Then, Submitting of Trenched Horizontal / Vertical Loop Design, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping | | | | | | | | |
| 1-a | Ground Testing for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |
| 1-b | Ground Loop Design for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AIR CONDITIONING -- Project Quote 16232-00

| | | | | Occ. 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|--|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 2 | Ground Closed Loop Hydrulic Piping Works | | | | | | | | |
| | Under Ground Geothermal closed loop; Trenched Horizontal / Drilled Vertical, Loop Piping works via HDPE System, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping of HDPE material c/w all required fittings to act as a heat exchanger same to cooling coil. Item complete with Backfill & Grouts for the piping jacket avoiding Air Gaps or seprations via grouting with Thermal Grouts of 60% Quartezil and 20% Cement, 10% Fly Ash, 10% Sand. Hydrulic Fluid of Antifreeze Water Based Solution as a water source refrigrant for Heat Pump to be supplied and equiped. | | | | | | | | |
| 2-a | Trenched horizontal HRZ Loop with 10 ft depth, Bore-hole 4 Inch | Ton | 30 | BADRY | 600 | 18,000 | 900 | 27,000 | 45,000 |
| 2-b | Drilled Vertical VER Loop with 200 ft depth, Bore-hole 6 Inch | Ton | 70 | BADRY | 800 | 56,000 | 1200 | 84,000 | 140,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AIR CONDITIONING -- Project Quote 16232-00

| | | | | O.C.C. I | Supp | oly (USD) | Erection (USD) | | Total Supply | |
|-----|---|------|-----|------------------|--------------|-----------|----------------|--------|---------------------|--|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) | |
| 3 | Geothermal System Equipments (GHP Equipments) | | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal water source Heat Pump with R-410a Refrigrant with wider fluid operating range and additional insulation of internal co-axial coils, thermal expansion TX Valves and heat exchangers optimized for geothermal operating conditions. GHP to be designed and supplied with Variable Flow System c/w two-way isolating valves at each heat pump that shut off the flow when the compressors is not runing. Heat Pump to be modulated and equipeed with variable frequency drive (VFD) | | | | | | | | | |
| 3-a | GHP c/w VFD for Variable Flow, 20 Ton (Cool Only) | No | 0 | AMRTA | 28000 | 0 | 4000 | 0 | 0 | |
| 3-b | GHP c/w VFD for Variable Flow, 25 Ton (Cool + Warm) | No | 4 | AMRTA | 53000 | 212,000 | 7000 | 28,000 | 240,000 | |
| 3-с | GHP c/w VFD for Variable Flow, 50 Ton (Heating / Child) | No | 0 | AMRTA | 67000 | 0 | 8000 | 0 | 0 | |
| 3-d | Rooftop Unit with Enthalpy Wheel | No | 1 | Mc-Quay | 49000 | 49,000 | 6000 | 6,000 | 55,000 | |
| 3-е | Templifier Water to Water Heat Recovery | No | 1 | Mc-Quay | 41000 | 41,000 | 4000 | 4,000 | 45,000 | |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AIR CONDITIONING -- Project Quote 16232-00

| | | | | Offered | Supply (USD) | | Erecti | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|--------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 4 | Pumping & Mechanical Room Works | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal system redundant pump package system to meet the design flow and to be connected and controlled with VFD of GHP. System to be complete with Supply & Return Headers @ Mechanical Rooms c/w pipes, fittings, taps and valves for supply / return lines and expansion tanks and air seprators to act the whole system operation more over system flushing; air removing from ground loop into piping | | | | | | | | |
| 4-a | Pumping System for Flow (1-Operation +1-Standby) | Pkg | 1 | Grundfos | 28000 | 28,000 | 4000 | 4,000 | 32,000 |
| 4-b | Mechanical Room Works c/w Headers, Valves, Accessories | LS | 1 | BADRY | 12000 | 12,000 | 6000 | 6,000 | 18,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR AIR CONDITIONING -- Project Quote 16232-00

| | | | | 0661 | Supp | oly (USD) | Erect | ion (USD) | Total Supply | |
|-----------|---|----------------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|--|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) | |
| 5 | Delivery / Distribution System | | | | | | | | | |
| 5-1 | SITC Water Transfer / Piping System c/w Valves & Fittings | LS | 1 | BADRY | 75000 | 75,000 | 25000 | 25,000 | 100,000 | |
| 5-2 | SITC Air Transfer / Ducting System c/w Registers & Dampers | LS | 1 | BADRY | 55000 | 55,000 | 20000 | 20,000 | 75,000 | |
| 5-3 | SITC Radiant Floor Warming System c/w Outlets | LS | 1 | BADRY | 85000 | 85,000 | 25000 | 25,000 | 110,000 | |
| 5-5 | Civil / Arch. Ancilaary Works to furnish Distribution System | LS | 1 | BADRY | 0 | 0 | 35000 | 35,000 | 35,000 | |
| 6 | Control & Management System | | | | | | | | | |
| 6-1 | DDC Control System | LS | 1 | Rockwell | 19000 | 19,000 | 4000 | 4,000 | 23,000 | |
| 6-2 | BMS / HDMI Operation System with PLC | LS | 1 | Rockwell | 22000 | 22,000 | 5000 | 5,000 | 27,000 | |
| 7 | Testing & Balance | | | | | | | | | |
| 7-1 | Testing & Ballancing of HVAC / Ducting / Piping Systems of Each Area Acc. To ASHARE / SMACNA / ISO Classification | LS | 1 | BADRY | 0 | 0 | 15000 | 15,000 | 15,000 | |
| S2 | GEOTHERMAL - SUM / AIR CONDITIONING WORKS | One Milion USD | | | | | | 1,000,000 | | |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING -- Project Quote 16233-00

| | | | | Oee 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 1 | Geothermal System Design & Ground Testing | | | | | | | | |
| | Ground Geothermal Sytem Testing & Designing, provides the designer with accurate information on the thermal conductivity, loop design can be optimized and the path of of piping and Bore-Holes. Tests with Field Testing Appartus will be conducted by drilling borehole and adding loop with hot water from a portable electric heater is circulated. Data log is run over 48 hours and energy absorbed by the ground is measured so that the conductivity and diffusivity could been calculated. Then, Submitting of Trenched Horizontal / Vertical Loop Design, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping | | | | | | | | |
| 1-a | Ground Testing for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |
| 1-b | Ground Loop Design for Geothermal of the Ventilation Area | LS | 1 | BADRY | 0 | 0 | 20000 | 20,000 | 20,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING -- Project Quote 16233-00

| | | | | Offered | Supp | ly (USD) | Erecti | ion (USD) | Total Supply |
|-----|--|------|-----|------------------|--------------|----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 2 | Ground Closed Loop Hydrulic Piping Works | | | | | | | | |
| | Under Ground Geothermal closed loop; Trenched Horizontal / Drilled Vertical, Loop Piping works via HDPE System, c/w Bore-Hole Layout using Software Design for Ground Loops, Piping of HDPE material c/w all required fittings to act as a heat exchanger same to cooling coil. Item complete with Backfill & Grouts for the piping jacket avoiding Air Gaps or seprations via grouting with Thermal Grouts of 60% Quartezil and 20% Cement, 10% Fly Ash, 10% Sand. Hydrulic Fluid of Antifreeze Water Based Solution as a water source refrigrant for Heat Pump to be supplied and equiped. | | | | | | | | |
| 2-a | Trenched horizontal HRZ Loop with 10 ft depth, Bore-hole 4 Inch | Ton | 30 | BADRY | 600 | 18,000 | 900 | 27,000 | 45,000 |
| 2-b | Drilled Vertical VER Loop with 200 ft depth, Bore-hole 6 Inch | Ton | 70 | BADRY | 800 | 56,000 | 1200 | 84,000 | 140,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING -- Project Quote 16233-00

| | | | | O.CC 1 | Supp | oly (USD) | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 3 | Geothermal System Equipments (GHP Equipments) | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal water source Heat Pump with R-410a Refrigrant with wider fluid operating range and additional insulation of internal co-axial coils, thermal expansion TX Valves and heat exchangers optimized for geothermal operating conditions. GHP to be designed and supplied with Variable Flow System c/w two-way isolating valves at each heat pump that shut off the flow when the compressors is not runing. Heat Pump to be modulated and equipeed with variable frequency drive (VFD) | | | | | | | | |
| 3-a | GHP c/w VFD for Variable Flow, 20 Ton (Cool Only) | No | 0 | AMRTA | 28000 | 0 | 4000 | 0 | 0 |
| 3-b | GHP c/w VFD for Variable Flow, 25 Ton (Cool + Warm) | No | 0 | AMRTA | 53000 | 0 | 7000 | 0 | 0 |
| 3-с | GHP c/w VFD for Variable Flow, 50 Ton (Heating / Child) | No | 3 | AMRTA | 67000 | 201,000 | 8000 | 24,000 | 225,000 |
| 3-d | Rooftop Unit with Enthalpy Wheel | No | 1 | Mc-Quay | 49000 | 49,000 | 6000 | 6,000 | 55,000 |
| 3-е | Templifier Water to Water Heat Recovery | No | 1 | Mc-Quay | 41000 | 41,000 | 4000 | 4,000 | 45,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING -- Project Quote 16233-00

| | | | | Occ. 1 | Supply (USD) | | Erect | ion (USD) | Total Supply |
|-----|---|------|-----|------------------|--------------|--------|--------------|-----------|---------------------|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) |
| 4 | Pumping & Mechanical Room Works | | | | | | | | |
| | Supply, installation, testing and commissioning of Geothermal system redundant pump package system to meet the design flow and to be connected and controlled with VFD of GHP. System to be complete with Supply & Return Headers @ Mechanical Rooms c/w pipes, fittings, taps and valves for supply / return lines and expansion tanks and air seprators to act the whole system operation more over system flushing; air removing from ground loop into piping | | | | | | | | |
| 4-a | Pumping System for Flow (1-Operation +1-Standby) | Pkg | 1 | Grundfos | 28000 | 28,000 | 4000 | 4,000 | 32,000 |
| 4-b | Mechanical Room Works c/w Headers, Valves, Accessories | LS | 1 | BADRY | 12000 | 12,000 | 6000 | 6,000 | 18,000 |





Table D - BOQ for Geothermal System



GEOTHERMAL SYSTEM FOR WATER / STEAM HEATING -- Project Quote 16233-00

| | | | | 0.66 | Supp | oly (USD) | Erect | ion (USD) | Total Supply | |
|-----|---|-----------------------------|-----|------------------|--------------|-----------|--------------|-----------|---------------------|--|
| S.N | Item Description | Unit | QTY | Offered Makes | Unit Rate | Amount | Unit Rate | Amount | & Erection (USD) | |
| 5 | Delivery / Distribution System | | | | | | | | | |
| 5-1 | SITC Water Transfer / Piping System c/w Valves & Fittings | LS | 1 | BADRY | 75000 | 75,000 | 25000 | 25,000 | 100,000 | |
| 5-2 | SITC Air Transfer / Ducting System c/w Registers & Dampers | LS | 0 | BADRY | 55000 | 0 | 20000 | 0 | 0 | |
| 5-3 | SITC Radiant Floor Warming System c/w Outlets | LS | 0 | BADRY | 85000 | 0 | 25000 | 0 | 0 | |
| 5-5 | Civil / Arch. Ancilaary Works to furnish Distribution System | LS | 1 | BADRY | 0 | 0 | 35000 | 35,000 | 35,000 | |
| 6 | Control & Management System | | | | | | | | | |
| 6-1 | DDC Control System | LS | 1 | Rockwell | 19000 | 19,000 | 4000 | 4,000 | 23,000 | |
| 6-2 | BMS / HDMI Operation System with PLC | LS | 1 | Rockwell | 22000 | 22,000 | 5000 | 5,000 | 27,000 | |
| 7 | Testing & Balance | | | | | | | | | |
| 7-1 | Testing & Ballancing of HVAC / Ducting / Piping Systems of Each Area Acc. To ASHARE / SMACNA / ISO Classification | LS | 1 | BADRY | 0 | 0 | 15000 | 15,000 | 15,000 | |
| S3 | GEOTHERMAL - SUM / HEATING WORKS | Eight Hundred Thousands USD | | | | | | 800,000 | | |





Water Source Heat Pump Unit

Cooling capacity from 10 to 133 kW Heating capacity from 12.1 to 156.2 kW

Functions







Cooling

C&H Heat Recovery



Characteristics

Structure

Panels and frame are made from galvanized steel protected with polyester powder painting to ensure total resistance to atmospheric agents

Hermetic compressor

Single phase (mod. 10, 12,15) and 3-phase (mod.17 to 130) scroll type compressors, with built-in thermal overload cut-out and crankcase heater, mounted on rubber vibration dampers

Evaporator

High efficiency plate type heat exchanger, factory insulated with flexible close cell material

Condenser

High efficiency plate type heat exchanger, factory insulated with flexible close cell material

Desuperheater

High efficiency stainless steel brazed plate heat exchanger, factory insulated with flexible close cell material

Refrigerant circuit

Copper tube connection with charge valves, filter drier, thermostatic expansion valve (capillary for mod.10 to 15), gas-liquid separator, high pressure switch and low pressure switch

The heat pump units are complete also with 4-way valve and one way valve

Hydraulic circuit

Built with user side and source side water inlet/outlet connectors, water discharge connectors, air vent valve (mod.10 to 30 the user side is complete also with expansion vessel, water pump and flow switch.)

Electric panel

Consists of:

- ♦ Compressor contactor
- ◆ Compressor protection breaker
- ◆ User side water pump contactor (for mod.10 to 30)
- ♦ User side water pump breaker (for mod.10 to 30)
- ♦ Microprocessor with function display

Optional

- ♦ Sight glass which must be installed in factory
- ♦ Source side flow switch
- ♦ Source side water pump
- ♦ Anti-vibration rubber
- ♦ Metallic filter for the water circuit
- ♦ Heat recovery exchanger
- ♦ Tube in tube heat exchanger

Technical Data R410a

| Model WW | Unit | 10 | 12 | ' | 15 | 20 | | 25 | | 30 | 40 | 45 | 50 |
|----------------------------|---------|------|----------|------|-----|----------|--------|------|------|-------|-------|-------|-------|
| Nominal cooling capacity* | kW | 10 | 12 | | 15 | 20 | | 25 | | 30 | 40 | 45 | 50 |
| Nominal heating capacity** | kW | 11.6 | 14 | 1 | 7.5 | 21 | | 27.3 | 3 | 34.6 | 41.7 | 47 | 55.9 |
| Power suplly | V/PH/Hz | | 220/1/50 | | | 380/3/50 | | | | | | | |
| Hermetic compressors | S | | | | | | | | | | | | |
| Qty | Nr. | 1 | 1 | | 1 | 1 | | 2 | | 2 | 2 | 2 | 2 |
| Cooling power input* | kW | 2.77 | 3.22 | 3 | .89 | 4.2 | 1 | 5.63 | | 7.09 | 8.24 | 10.4 | 11.04 |
| Cooling current* | Α | 13.8 | 16.2 | 1 | 9.1 | 7.8 | , | 10.6 | Ċ. | 12.8 | 14.9 | 18.8 | 20.1 |
| Heating power input** | kW | 3.51 | 4.15 | 5 | .05 | 5.76 | 6 | 7.63 | | 9.69 | 11.34 | 13.97 | 14.77 |
| Heating current* | Α | 17.1 | 20.3 | 2 | 4.5 | 10.2 | 2 | 13.6 | ; | 16.8 | 19.7 | 24.3 | 25.8 |
| User side heat exchan | iger | | | | | | | | | | | ' | • |
| Pressure drop | kPa | 33 | 33 | | 36 | 38 | | 38 | | 38 | 40 | 40 | 42 |
| Water flow | m³/h | 1.7 | 21 | 2 | 2.6 | 3.4 | | 4.3 | | 5.2 | 6.9 | 8.1 | 8.6 |
| Water pipe | DN | 25 | 25 | 1 | 25 | | | 40 | | 40 | 40 | 40 | 40 |
| Source side heat exch | anger | | l. | | | | | | | | | | |
| Pressure drop | kPa | 33 | 33 | - ; | 36 | 38 | | 38 | | 38 | 40 | 40 | 42 |
| Water flow | m³/h | 0.7 | 0.8 | | 1 | 1.2 | ! | 1.6 | | 2 | 2.5 | 2.5 | 3.3 |
| Water pipe | DN | 25 | 25 | 5 25 | | 25 | 5 40 | | | 40 | 40 | 40 | 40 |
| Water pump | ' | | ı | | | | | | | | | | 1 |
| power input | kW | 0.4 | 0.49 | 0 | .49 | 0.55 | 5 | 0.75 | ; | 0.75 | 0.92 | 1.05 | 1.05 |
| current | Α | 2.2 | 2.4 | 2 | 2.4 | 1.1 | | 1.2 | | 1.2 | 1.5 | 2 | 2 |
| Water head | m | 17 | 20 | | 18 | 16 | | 19 | | 16 | 17 | 18 | 17 |
| | L | 820 | 820 | 8 | 20 | 820 |) | 1400 |) | 1400 | 1400 | 1400 | 1400 |
| Dimension(mm) | W | 575 | 575 | 5 | 75 | 575 | 5 | 850 | | 850 | 850 | 850 | 850 |
| | Н | 910 | 910 | 9 | 910 | | 0 1050 | |) | 1050 | 1050 | 1050 | 1050 |
| Sound pressure level*** | dB(A) | 56 | 58 | (| 62 | 62 | | 62 | | 64 | 64 | 66 | 66 |
| Net weight | kg | 130 | 140 | 1 | 50 | 180 |) | 265 | | 280 | 320 | 340 | 360 |
| | | | • | | | | | • | | | | ' | • |
| Model | Unit | 55 | | 60 | 6 | 8 | | 75 | | 95 | 110 | 130 | 150 |
| Nominal cooling capacity* | kW | 56 | | 62 | 6 | 9 | | 75 | | 94 | 113 | 130 | 150 |
| Nominal heating capacity** | kW | 62.2 | 2 7 | 70.1 | | 76.4 | | 83.4 | | 105.1 | 124.1 | 140.1 | 165.4 |
| Power suplly | V/PH/Hz | | | | | | | 380/ | 3/50 |) | | | |
| Hermetic compressors | S | | | | | | | | | | | | |
| Qty | Nr. | 2 | | 2 | : | 2 | | 4 | | 3 | 3 | 4 | 4 |
| Cooling power input* | k/M | 11.0 | 3 1 | 2 66 | 13 | 3.7 | 1. | 1 61 | | 18 00 | 22 11 | 25.32 | 20.48 |

| Model | Unit | 55 | 60 | 68 | 75 | 95 | 110 | 130 | 150 | |
|----------------------------|------------------|-------|-------|-------|-------|-------|-------|-------|-------|--|
| Nominal cooling capacity* | kW | 56 | 62 | 69 | 75 | 94 | 113 | 130 | 150 | |
| Nominal heating capacity** | kW | 62.2 | 70.1 | 76.4 | 83.4 | 105.1 | 124.1 | 140.1 | 165.4 | |
| Power suplly | V/PH/Hz 380/3/50 | | | | | | | | | |
| Hermetic compressors | | | | | | | | | | |
| Qty | Nr. | 2 | 2 | 2 | 4 | 3 | 3 | 4 | 4 | |
| Cooling power input* | kW | 11.03 | 12.66 | 13.7 | 14.64 | 18.99 | 22.11 | 25.32 | 29.48 | |
| Cooling current* | Α | 19.6 | 22.8 | 24.3 | 26.8 | 34.2 | 38.7 | 45.6 | 51.6 | |
| Heating power input** | kW | 15.41 | 17.02 | 18.71 | 20.84 | 25.53 | 30.6 | 34.04 | 40.8 | |
| Heating current* | Α | 26.3 | 29.4 | 31.9 | 36.4 | 44.1 | 51.6 | 58.8 | 68.8 | |
| User side heat exchanger | | | | | | • | | | | |
| Pressure drop | kPa | 42 | 48 | 48 | 50 | 52 | 52 | 55 | 55 | |
| Water flow | m³/h | 9.6 | 10.7 | 11.9 | 12.9 | 16.2 | 19.4 | 22.4 | 25.8 | |
| Water pipe | DN | 50 | 50 | 50 | 50 | 65 | 65 | 80 | 80 | |
| Source side heat exchange | jer | | | • | • | • | | • | | |
| Pressure drop | kPa | 42 | 48 | 48 | 50 | 52 | 52 | 55 | 55 | |
| Water flow | m³/h | 3.7 | 4.1 | 4.5 | 4.9 | 6.2 | 7.3 | 8.3 | 9.7 | |
| Water pipe | DN | 50 | 50 | 50 | 50 | 65 | 65 | 80 | 80 | |
| Water pump | | | | | | • | | | | |
| Power input | kW | 1 | 1 | 1 | 1 | / | 1 | 1 | 1 | |
| Current | Α | 1 | 1 | 1 | / | / | 1 | 1 | 1 | |
| Water head | m | 1 | 1 | 1 | 1 | / | 1 | 1 | 1 | |
| | L | 1400 | 1400 | 1400 | 1400 | 1400 | 1850 | 1850 | 1850 | |
| Dimension(mm) | W | 850 | 850 | 850 | 850 | 850 | 880 | 880 | 880 | |
| | Н | 1050 | 1050 | 1050 | 1050 | 1050 | 1250 | 1250 | 1250 | |
| Sound pressure level*** | dB(A) | 68 | 72 | 72 | 72 | 73 | 73 | 74 | 74 | |
| Net weight | kg | 280 | 300 | 340 | 360 | 460 | 500 | 550 | 620 | |

Performance values refer to the following conditions:

^{*} Source side water inlet/outlet temperature 18°C/29°C, user side water inlet/outlet temperature 12°C/7°C.

^{**} Source side water inlet/outlet temperature $15^{\circ}\text{C}/7^{\circ}\text{C}$, user side water inlet/outlet temperature $40^{\circ}\text{C}/45^{\circ}\text{C}$.

^{****} Sound pressure measured at a distance of 1 m and a height of 1.5 m above the ground in an open field.



شركة البدرى للأعمال الكهروميكانيكية

إحدى شركات مجموعة البدرى للتنمية والاستثمار

BADRY Electro-Mechanical Works Co.







BADRY Group Member

MEP Systems Design & Build

MEP Engineering & Solutions

MEP Project Management

MEP Systems Operation & Maintenar

MEP Infrastructure Networks

MEP Landscape & Irrigation

Power Distribution & Transmission

Control & Automation

Substations / Plants

Electrical Networks

Panel Fabrication

Lighting Applications

Mechanical Works

Instrumentation / Valves

Pumps / Compressors

Plumbing / Piping

HVAC / Ducting


Fire Fighting

Industrial Installations

Metal & Steel Structure

Skilled Craftsmanship

Safety Information



















6B, sixth October St. Manshiet Al Sad Al Aaly. Al-salam, Cairo, Egypt.

Tel: +202 2190 6401, +202 2190 6823

Fax: +202 2190 6823 - Cell: +20 100 5743 852

E-mail: mep@badrygroup.com Web: www.badrygroup.com

